



TYPICAL FIRE HYDRANT ASSEMBLY

NOT TO SCALE

NOTE:

1. ROMAC "GRIP-RING" MECHANICAL JOINT ACCESSORY KITS SHALL BE USED ON ALL MECHANICAL JOINT CONNECTIONS FROM VALVE TO HYDRANT.
2. MINIMUM HYDRANT DEPTH IS 4 FEET.
3. SHACKLE RODS MAY BE USED IN PLACE OF "GRIP-RINGS" OR A THRUST BLOCK WHEN APPROVED BY THE PUBLIC WORKS DIRECTOR.

• ONLY THE LATEST DETAIL, AS APPROVED BY THE DIRECTOR OF PUBLIC WORKS, SHALL BE USED.

REV.	01/12	ADDED SHACKLE ROD NOTE	
ORIG.	10/06		
Revision	Date	Description	Appr