



FIRE SERVICE

NOT TO SCALE

NOTES:

- ONLY THE LATEST DETAIL, AS APPROVED BY THE DIRECTOR OF PUBLIC WORKS, SHALL BE USED.
- FIRE SERVICE SHALL BE INSTALLED W/ A MINIMUM OF 3" THICKNESS C.S.T.C. PIPE BEDDING ON ALL SIDES

REV.			
ORIG.	09/14		
Revision	Date	Description	Appr